

10 PSF (49 kg/m^2) SNOW/WIND LOAD

90 PSF (438 kg/m²) WIND UPLIFT FORCE


102mm|

127mm


40 PSF (195 kg/m^2) LIVE LOAD 3. COVERS WILL REMAIN CLOSED UNDER

2. VENT ASSEMBLY RATED FOR


4. STC-46 SOUND RATING



THERMOLATCH[®] II CURB - MOUNTED RESET



- 1. THERMOLATCH MECHANISM COVERS WILL OPERATE ONLY WHEN ACTIVATED A. MANUALLY
 - B. BY HEAT AT 165° FUSIBLE LINK
- 2. MANUFACTURER TO PROVIDE LABEL WITH INSTRUCTIONS TO RESET LATCH ON INTERIOR OF FRAME



SPECIFICATIONS

- 1. CURB, FULLY ENCLOSED WITH INTEGRAL CAPFLASHING (CORNERS FULLY WELDED) -14 GA. P.B. GALV. STEEL
- 2. COVER 14 GA. P.B. GALV. STEEL
- 3. COVER LINER 14 GA. P.B. GALV. STEEL
- 4. 3" CURB INSULATION
- 5. 3" COVER INSULATION
- 6. GASKET (ALL AROUND)
- 7. PIANO HINGE
- 8. BILCLIP® FLASHING SYSTEM
- 9. FIXED CENTER DRAIN
- 10. GAS SPRINGS WITH DAMPER & HOLD OPEN FEATURE
- 11. COVER RESTRAINT CABLE
- 12. COVER LATCH BRACKET
- 13. THERMOLATCH $^{f R}$ II POSITIVE HOLD/RELEASE MECHANISM
- 14. 165° FUSIBLE LINK (EXTRA LINK PROVIDED)
- 15. INTERIOR PULL RELEASE CABLE
- 16. EXTERIOR PULL RELEASE CABLE

SHOP FINISH

STEEL: HARDWARE:

RED OXIDE PRIMER CORROSION RESISTANT (UNLESS OTHERWISE SPECIFIED)

NOTES:

- 1. THIS PRODUCT MAY BE INSTALLED ON EITHER A FLAT OR SLOPING ROOF. WHEN INSTALLED ON A SLOPE, THE HINGE SIDE MUST RUN PARALLEL WITH THE SLOPE. IF SLOPE EXCEEDS 30°, ADVISE FACTORY FOR MODIFICATION.
- 2. FULL SPECIFICATIONS ARE AVAILABLE ON WEBSITE: www.bilco.com

CUSTOMER		

P.O. NO.

SALES REP



Manufacturers of Doors for Special Services BILCO COMPANY New Haven, Connecticut 06505

DOUBLE LEAF SMOKE VENT TYPE ACDSH

MODEL QTY

S	Z	Έ
WIDTH	×	LENGTH

THIS DRAWING IS THE PROPERTY OF THE BILCO COMPAN AND INCORPORATES INFORMATION WHICH IS PROPRIETARY. PUBLICATION AND/OR PUBLIC DISTRIBUTION IN WHOLE OR IN PART IS EXPRESSLY PROHIBITED WITHOUT THE PRIOR WRITTEN CONSENT OF THE BILCO COMPANY. THE INFORMATION CONTAINED HEREIN REMAINS THE PROPERTY OF THE BILCO COMPANY. ALL RIGHTS RESERVED.

187mm

HINGE SIDE